

Ammonia Storage Tank Pre -Commissioning

Prem Baboo
DGM (Production & process)

Abstract:- In Fertilizers Industries surplus ammonia is stored in a large capacity tank. For efficient discharge and storage of hazard chemicals such as ammonia, special processes must be developed, and several related parameters must be checked and evaluated. The Nitrogen purging is the very important activities before taking ammonia in the storage tank and purging aim to reduce the Oxygen content in the tank below the lower flammable limit that is 16%, during the purging the tank may be exposed to conditions which could cause damage. This is the process whereby a safe atmosphere is established within the process equipment. Therefore extreme care was taken to prevent over pressurizing the tank or subjecting it to thermal stress beyond its design. The purging is carried out until the Oxygen Concentration of <8.0 % is reached. In this article hydraulic test and pneumatic test final settlement of the tank were studied, pressure changes in ammonia storage systems that are purged by nitrogen gas, during filling by Nitrogen purging, the amount of Nitrogen were calculated.

Keywords:- Ammonia storage, Purging Ammonia Nitrogen, Cryogenic, ammonia pump, Vaporiser, Oxygen analyser, foundation levelling settlement.

INTRODUCTION

Dangote Fertilizer Project consists in the realization of an Ammonia and Urea complex with associated facilities. The Project under progress at LEKKI Free Zone in Ibeju-Lekki Local Government Area of Lagos State, Nigeria.

Ammonia and Urea complex includes:

2x2200 MTPD Ammonia Trains based on HTAS technology (and BASF technology for CO₂ capture in Ammonia Plants).

2x3850 MTPD Melt Urea Trains based on Saipem Technology.

2x3850 MTPD Urea Granulation Trains based on Udhe Fertilizer technology. Associated Utility Units.

For ammonia storage 20000MT capacity double wall tank is installed for train-1 & train -2.

AMMONIA STORAGE BRIEF DESCRIPTION

In ammonia Plant ammonia is produced from synthesis gas containing hydrogen and nitrogen in the ratio of approximately 3:1. Besides these components, the synthesis gas also contains inert gases such as argon and methane to a limited extent. The source of H₂ is demineralized water (steam) and the hydrocarbons in the natural gas. The source of N₂ is the atmospheric air. The source of CO₂ is the hydrocarbons in the natural gas feed. Product ammonia and CO₂ is sending to urea plant. The main function of the plant is illustrated in the figure-1




Fig.-1

Ammonia Storage System mainly covers the requirements of Liquid Ammonia Storage, transfer of liquid ammonia and ammonia vapour from/to Ammonia-Urea Plants, Storage Refrigeration and Flaring of Ammonia Vapours during emergency conditions. The unit includes the following functional sections:

1. Ammonia Storage Tank (30-T-01)
2. Transfer of Liquid Ammonia from Ammonia plants to Urea plants by Ammonia Process transfer pumps (30-P-01).
3. Transfer of Ammonia Vapour to Ammonia Plants by Ammonia Vapour Displacement Blower (30-U-01)
4. Ammonia Stand-by Refrigeration Package (30-PK-02)
5. Ammonia Storage Flare (30-PK-01)
6. Ammonia Drainage Pit (30-CB-01)

Liquid ammonia is transferred from Ammonia Units (Train 1 or 2) to the Ammonia Storage Tank. Details of the tank as follows:

Ammonia storage Tank

Sr. No.	Name of Items	Value
1	Number of Tank	1
2	Capacity	20000 MT of Liquid Ammonia
3	Operating Pressure, in/Max	200/400 mm H ₂ Og
4	Operating Temperature	-33 °C
5	Max daily Boiled- off	0.04% by weight of full storage capacity
6	Ammonia Transfer pump Capacity	148.4 m ³ /h

Table-1

Ammonia Vapour Displacement Blower is designed to transfer the ammonia vapour generated from Ammonia Storage tank to Ammonia Plants. In normal operation the excess ammonia vapour is sent to the Ammonia Process Plant by means of Ammonia vapour displacement blower for further recovery in the main Process Refrigeration Unit. In case such routing is not possible, or in case of pressure rise in the ammonia storage tank above the normal operating range, the excess ammonia vapours are compressed and condensed by the dedicated Ammonia Stand-by Refrigeration unit. The maximum capacity of the Blower the design flow-rate of 800 Nm³/which is equivalent to 610 kg/ammonia Stand-by Refrigeration Package The ammonia refrigeration package is to maintain at -33°C the liquid ammonia contained in the Ammonia Storage Tank. In case the pressure in the ammonia Storage Tank rises above the normal operating value, the ammonia vapours are sent to the Ammonia Storage Stand-by Refrigeration Package .where they are compressed and condensed and then sent back to the Ammonia Tank .The Package is composed of the following main items: Screw compressor, oil separator, Oil Cooler, Condenser, liquid receiver, economizer and saturator. The operating ammonia flow rate is 780 kg/h. The package is designed for an ammonia flow rate of 860 kg/h at maximum load.

AMMONIA STORAGE FLARE.

Ammonia Storage Flare is dedicated to Ammonia storage section and it is sized considering the worst scenario of the system, i.e. Ammonia BOG Compressor Blocked Outlet condition with a Blow-down Gas flow-rate of 1132 Nm³/h (860 kg/h), LHV of Blow down gas is 3375 Kcal/Nm³.The maximum consumption of Fuel Gas necessary to assist the complete combustion of the ammonia gas, discharged at the said flow rate is minimized. The estimated consumption of fuel gas is 130 kg/h, during the emergency flaring of the design stream. The Total height of the stack is 15 meter, Stack diameter 10”and stack design pressure is 3.5 kg/cm².

The Ammonia Storage Tank is double containment, designed and constructed so that both the primary and secondary self-supporting containers shall be capable of independently containing the stored liquid. Both inner & outer tank walls and bottoms are made of low temperature materials and are designed for product deriving loads. Since the insulation system is outside the outer tank, both inner and outer tank operate at product temperature, resulting in minimum product flash in the event of a product spill into the outer tank. The secondary containment structure is independent from that of the primary tank. Ammonia storage tank is equipped and provided with the necessary instrumentation capable of monitoring and controlling both normal operation and emergency occurrences, while assuring the highest reliability and operability. Ammonia Storage Tank is provided with pressure relief valves and with vacuum relief valves adequate to manage any emergency. Furthermore the tank is provided with nitrogen line and distribution ring at tank bottom; nitrogen will be used for purging operations on the tank prior to introduce ammonia, distribution ring to be used during tank cool down; nitrogen is also used to avoid vacuum, in case of unforeseen operations.

Inner Tank-The inner tank shall be full integrity, self-supporting, open top with suspended deck (insulation installed on the suspended deck), with dome roof (umbrella type).The inner tank is made up of steel suitable for the design temperature and designed in accordance with the required standards.

Sr.No.	Parameters	Value
1	Working Capacity	29370 m ³ , or, 20000 MT
2	Dimension, ID/H	38 meter/28.2 meter.
3	Operating Pressure Min/Max	200/400 mm H ₂ O
4	Design Pressure vacuum	-50 mm Hg
5	Design Pressure	1500 mm H ₂ O

Table-2

Outer Tank-The outer container (bottom + wall) are designed in accordance with the API Standard requirements and able to contain the entire liquid content in case of inner tank leak. It shall be vapour tight type and externally insulated. The annulus between the internal and external wall is covered to prevent rain water entrance into the annular space.

Liquid ammonia from Ammonia Plant (Train 1 or 2) can be transferred to the Ammonia Storage Tank through ammonia transfer line (8 inch). The same ammonia transfer line (8 inch) can be used to transfer the cold ammonia from Storage Tank to Urea Plant (Train 1 or 2) through the Ammonia Process Pump during upset of any one of the ammonia plants. Liquid ammonia is transferred to Urea Plants at following conditions:

Sr. No.	Parameters	value
1	Normal Flow rate	91.67 T/H
2	Design Flow rate	100 T/h
3	Temperature	-33°C
4	Operating Pressure	27 kg/cm ²

Table-3

NITROGEN REQUIRED FOR AMMONIA STORAGE TANK PURGING

Nitrogen purging is easily adapted to any process installation. Different methods are used depending on the type and shape of the equipment to be purged and on the location of the purging inlets and outlets. Two operations involve replacement of inert gas in tanks, namely:

(a) **Dilution, which is a mixing process;**

(b) **Displacement, which is a layering process.**

In each of these replacement operations, one of two processes can predominate. These two processes have a marked effect on the method of monitoring the tank atmosphere and the interpretation of the results. The dilution theory assumes that the incoming inert gas mixes with the original gases/vapours to form a homogeneous mixture throughout the tank vapour space; the result is that the concentration of the original gas/vapour decreases exponentially. In practice, the actual rate of gas/vapour replacement depends upon the volume flow of the incoming inert gas, its entry velocity and the dimensions of the tank vapour space. For complete gas/vapour displacement, it is important that the entry velocity of the incoming inert gas be high enough for the jet to reach the full vapour space; it is therefore important to confirm the ability of every installation using this principle to achieve the required degree of gas replacement throughout the tank vapour space. We can calculate moles of gas in ammonia storage tank and start and end, and assume this difference came from the nitrogen tank. Note you must use absolute temperature in kelvins (add 273.15) and ammonia storage tank pressure (add typical atmospheric pressure of 1.01 bar) for all temperature and pressure.

At end of cycle, moles of gas $n_f = (1/R) \cdot P_f \cdot V_a / T_f$

At start of cycle, $n_i = (1/R) \cdot P_i \cdot V_a / T_i$

The gas from the nitrogen tank $n_t = n_f - n_i$,

but its volume is given (at tank pressure and temperature) by $V = n_t \cdot R \cdot T_t / P_t$

Substituting, the gas constant cancels out yielding

$$V_t = (T_t / P_t) \cdot V_a \cdot (P_f / T_f - P_i / T_i)$$

Where, i and f subscripts denote initial and final conditions in Ammonia storage tank, t for tank conditions (or the pressure and temperature you want the nitrogen volume stated at. V_a is the volume of the ammonia tank, reduce for volume occupied by the parts. We assumed atmospheric conditions for Nitrogen tank.

$V_a = 40766 \text{ m}^3$, $P = 0.381 \text{ bar}$, $T_i = 298.75$, $P_f = 1.093 \text{ bar}$,

We get $V_t = (298.75 / 0.381) \cdot 40766 \cdot (1.093 / 340.35 - 0.393 / 298.75)$

$(784.120) \cdot 40766 \cdot (0.003251 - 0.000131)$

$(784.120) \cdot 40766 \cdot (0.003119)$

$V_t = 101969.74 \text{ m}^3$

Hence the nitrogen required for purging is 101969.74 m^3

We get $V_t = (298.75 / 0.381) \cdot 40766 \cdot (1.093 / 313.35 - 0.393 / 298.75)$

$(784.120) \cdot 40766 \cdot (0.0034881 - 0.000131)$

$(784.120) \cdot 40766 \cdot (0.003357)$

$V_t = 107311.74 \text{ m}^3$

NITROGEN PURGING OF AMMONIA TANK						
Sr. No.	Date	Pressure of Tanker	Evaporator outlet Pressure	Pressure Ammonia storage inlet, Bar	Pressure inside the Ammonia tank, bar	Oxygen Content
1	12-09-2019	7.1	4.4	2.4	0.071	20.80%
2	13-09-2019	7.0	4.3	2.3	0.078	19.70%
3	14-09-2019	7.4	4.7	2.7	0.065	18.30%
4	15-09-2019	7.3	4.6	2.6	0.079	16.80%
5	16-09-2019	7.3	4.6	2.6	0.070	15.60%
6	17-09-2019	7.1	4.4	2.4	0.069	14.80%
7	18-09-2019	7.5	4.8	2.8	0.069	13.80%
8	19-09-2019	7.4	4.7	2.7	0.063	13.20%
9	20-09-2019	7.3	4.6	2.6	0.065	12.70%
10	21-09-2019	7.2	4.5	2.5	0.066	11.60%
11	22-09-2019	7.5	4.8	2.8	0.064	10.30%
12	23-09-2019	7.4	4.7	2.7	0.067	9.80%
13	24-09-2019	7.3	4.6	2.6	0.065	9.10%
14	25-09-2019	7.1	4.4	2.4	0.064	7.40%

Table-4

DISPLACEMENT PURGING

This method is used for equipment replacing the present air in the vessel. The volume of nitrogen required corresponds to the physical volume of the vessel. The nitrogen volume required to purge equipment with a vessel is determined using the following formula.-

$$V=V_o \cdot P$$

Where V= Total Nitrogen volume required.

V_o =Water Volume of Tank (m^3)

P=Absolute pressure of Nitrogen in the tank during the purging.

Hence the Required Nitrogen Volume= $V_o \cdot P$

$$40766 \cdot 2.6 = 105991 \text{ Nm}^3$$




Fig.-2

Initially rate was maintained higher about 1500-1600 Nm³/hr, but after 8 hrs. The rate was reduced after achieved the tank positive pressure. The rate was maintained one third of the initial rate means the rate was about 300-400 Nm³/Hr. So time was taken for total purging including mobilization purging operation and demobilization was 11-12 days completed. Since the Nitrogen and air have similar specific gravity. The Nitrogen is expected to mix with air it enters the inner tank with complete mixing in the tank, The Nitrogen quantity required to reduce the Oxygen Contents theoretically one time the tank volume about 40766 Nm³, apart from above the thumps rule the required volume of Nitrogen is 2.5 to 3.0 times of ammonia storage volume, so roughly figure is 100000Nm³ to 110000 Nm³.

LIMITS OF EXPLOSIVE

The limiting oxygen concentration (LOC) is defined as the limiting concentration of oxygen below which combustion is not possible, independent of the concentration of fuel. It is expressed in units of volume percent of oxygen. The LOC varies with pressure and temperature. It is also dependent on the type of inert (non-flammable) gas being used. The limiting of the concentration of oxidant in a fuel-oxidant-diluent mixture, below which an ignition. And/or subsequent deflagration cannot occur, under specified conditions, may be achieved by maintaining an atmosphere that is inert in the vapour space of a container or vessel. The addition of an inert diluent to a mixture of combustible material and oxidant affects the lower and upper flammable limits and the limiting oxidant concentration. The figure below shows a typical flammability diagram that represents a mixture of a combustible gas; an inert gas, Nitrogen; and an oxidant, oxygen at a given temperature and pressure. A mixture of air (79 percent N₂ and 21 percent O₂ by volume) and combustible gas is represented by the line formed by points DABE. As shown in the figure-3. A given mixture of the combustible gas and air, whether ignitable or not, is specified by a point on this line. Point A indicates the upper flammable limit of this mixture, and point B represents its lower flammable limit. Any point within the area bounded by FBCAGF is in the flammable range and can be ignited.




Fig-3

Any point outside this area represents a mixture that cannot be ignited. Point C represents the limiting oxidant concentration to prevent ignition; any mixture containing less oxygen cannot be ignited. Any mixture of oxygen and combustible gas alone is represented by the left side of the triangle. Any mixture of Nitrogen and combustible gas alone is represented by the right side of the triangle.

HYDRAULIC AND PNEUMATIC TEST OF AMMONIA STORAGE TANK

The hydraulic test, foundation settlement & pneumatic test were carried out from 06/8/2018 to 10/09/2018. The inner tank filling rate was 1030 m³/hr (that correspond to 914 mm of depth per hour). During the filling of the tank the roof man hole was kept open. The filling up of tank was executed in four steps. The settlement of foundation was checked in every step.

Sr. No.	Steps	Filled level	Equivalent height	Hold time.
1	1 st	¼ H	6940 mm	24 hrs.
2	2 nd	1/2H	13875 mm	24 Hrs
3	3 rd	¾ H	20810 mm	24 Hrs
4	4 th	H	27750 mm	48 Hrs

Table-5

FOUNDATION SETTLEMENT CHECKED

Foundation settlement was checked as per API 620. The value was recorded below table No-7

The level was taken corresponding to 8 points on outer tank wall. The bottom profile was checked 8 axes before hydrostatic & pneumatic test the value recorded in table No.6

Position	Location of different angles							
	0°	45°	90°	135°	180°	225°	275°	315°
Elevation(mm)	2150	2154	2140	2160	2158	2166	2149	2160
Deviation(mm)	2149	2154	2138	2164	2156	2160	2145	2149

Table-6

Load at Shell & Bottom								
Sr. No.	Parameters	Unit	Outer Tank			Inner Tank		
			Erection	Operating	Hydro test	Erection	Operating	Hydro test
1	Total Vertical Load	KN	12203	227215	12203	6305	220628	321022
2	Design Internal Pressure	KN/m ²	147100
3	Test Internal Pressure	m bar	183875
4	Design External Pressure	m bar	-4900
5	Liquid Pressure in Operating	KN/m ²	171101	188978
6	Liquid Pressure in Hydro test	KN/m ²	277500

Table-7




Fig-5

PNEUMATIC TEST OF AMMONIA STORAGE TANK

After hydraulic test was completed, with the tank full of water at requested level, all roof shell nozzles were blinded and tightened. Injection of air in the vapour space to the test pressure and equal to 1.25 times the design pressure ($1500 \times 1.25 = 1875$ mm water column), in different steps of about 500 mm WC each with a holding time of about 15 minutes each. The pressure was hold at least one hour. In order to allow an inspection of the tank of sign of distress. The pressure was slow released until design pressure (1500 mm water column). Visual examination was carried out of all joints of the wall. Welding joints around man ways and other connections. While the latter pressure was hold (1500 mm WG). a solution film was applied to all the welding on the external of the roof including compression ring and nozzles. The weld joints of outer tank were tested with solution film examination, as well.

CHECKED OF PSV.

1. Blinds were removed from pressure released valves PSV 81543/5154. Checked of pressure relief valves by injecting air into the tank of the tank. Valves were started to release the air at set pressure of 1650 mm WG.
2. Slow released of pressure until 1500 mm WG. Blinds was removed from pressure relief valves PSV8159/5160. Checked of pressure relief valves by injecting air into the top tank.
3. Slow released of until 1350 mm WG. Blind was removed from pressure relief valves PSV8157/5158 Checked the pressure relief valves by injecting air into the top of the tank. The valve was start to released air at the set pressure of 1500 mm WG.
4. Slow released of pressure until 1200 mm WG. Blinds were removed from pressure relief valves PSV 8155/5156. Checked of pressure relief valves by injecting air into the top of the tank. Valves were start to released air at the set pressure of 1200 mm WG.




Fig-6

5. Pressure in the vapour space was released.
6. Vacuum was checked with standing and vacuum relief valves operation, by withdrawing water from the tank with all vents closed. Vacuum valves 8161/8162/8163. was started to opened at the set pressure of -30 mm WG.
7. The tanks are very sensible for collapsing to extra vacuum action; an accurate monitoring of vacuum valves is very important during testing of vacuum valves. The partial vacuum in the tank was never exceeding the design value of -50 mm WG.

8. Before starting the emptying the tank was vented to atmosphere, roof manhole and/or other roof fitting having as large an area as the water inlet was open before filling vessel with water.
9. Withdrawal of all water, the tank was emptied out and be at atmospheric pressure.
10. During of all testing operation including filling and emptying, recorder pressure and temperature were connected to the vessel.




Fig-7

MATERIAL & METHOD.

Following material were arranged from local market.

1. Nitrogen Trailer with liquid Nitrogen
2. One trailer with vaporizer(1500Nm³/Hr.)
3. 1 set of Hoses and manifold with pressure & Temperature Gauge.
4. Ammonia reciprocating pump before vaporizer.
5. Oxygen analyser.
6. Explosive meter.

Tank with liquid Nitrogen was connected to vaporizer through cryogenic hose. The vaporizer outlet was connected to manifold through ¾" hose then from manifold to injection point on the blind flange of the roof nozzle about 1m(max) with a ¾" ball valve. The manifold, pressure & Temperature gauge fitted for monitoring data. These equipment's and quantity of liquid Nitrogen were mobilized at once to provided 24 hours operation. The team were organized into two shift to operate the change between tanks ensuring continuity to the operation, it was not take more than 15 minutes to connect another full since full tanks was outside. The total duration was 12- 13 complete days including mobilization, purging operation and demobilization. The evaporation system flow was 1200-1300 Nm³/Hr, the 5 hours was taken to reach 0.98 atm pressure. Then purging was carried out till <8 % of Oxygen Content.




Fig.-8

NITROGEN DRY-OUT & PURGE.

The Nitrogen was introduced into the tank via 3" roof nozzles as shown in the fig-9 with internal extension to the tank bottom and a central distribution ring.

The temperature of Nitrogen Vapour was same or higher than tank temperature to avoid condensation of the water in air. When the pressure of the tank was reached about 500 mm WG, the purging was started from top of the roof. Sample was also collected initially. The tank pressure was also maintained at the same pressure by adjusted Nitrogen purging flow. When the Oxygen contents below 8% then the annulus ring connected and roof vent is closed now purging started through annulus vent. The annulus oxygen was monitored at each of the three annular purge ring outlet nozzles. when the oxygen content is below 8% then the roof vent nozzle was opened again and the annular purge ring outlet nozzle was closed. The final result was 7.4% each tank vent and also annulus. This alternating procedure was repeated several times. It was advantageous to hold the pressure for several hours and allow the Nitrogen/air mixture to stabilize before finalizing the purge. The Nitrogen purge was completed at 8 % oxygen was reached from all nozzles.

DATA COLLECTION

In general data was collected according to the following schedule for the Nitrogen purge.

1. One sample every 4 hours was reached during operation during the Nitrogen purge.
2. The above durations adjusted during the operation by the coordinator in addition to the regular based reading, data was collected, events noted at event points such as change of flow rates, opening or closing of vents, and others mechanical changes.




Fig-9

PRE COMMISSIONING ACTIVITIES

Pre commissioning was covering all the necessary preparation for the safe and efficient Nitrogen purge, product vapour purge and cool down.

The following list for pre commissioning activities

1. Verified that all instrumentation on tank and piping is operational.
2. Verified all construction equipment was removed from the area.
3. Confirmed that a lead man for commissioning been name.
4. Verified that the shell and roof man hole been closed.
5. Verified that the tank and process area had been roped off and was properly signposted. To prevent unauthorised personal from entering the area.
6. Verified that any live wires or electrical equipment not suitable for explosive atmosphere had been removed from the tank and process area.
7. Verified that pressure and vacuum safety relief valves had been checked installed and was operational.
8. Confirmed that tank had been tested, cleaned and mopped dry of any standing water.
9. Verified that a temporary water manometer had been connected to the tank to accurately read tank pressure during the Nitrogen. Purge.
10. Verified that a temporary vent stack and valves had been installed on nitrogen outlet connections.



Fig-10

TANK CLEANING

The Tank and internals appurtenances were cleaned with fresh water with dryer.

1. The surface of the inner bottom plates was cleaned after the tank emptied out.
2. All sand and sludge on the inner tank bottom was removed.
3. After final draining and drying surface of the inner tank bottom was cleaned by brush bottom and vacuum cleaner.
4. All stainless steel internal piping in contact with tank test water was cleaned with fresh water.

The ammonia storage tank bottom is flat. The shell measurements were executed after hydrostatic test of the tank. The all work was done our qualified staff.

VISUAL INSPECTION.

Periodical visual inspection during the whole period of test execution was performed in order to detect whether extraordinary appearance are present or not. Very careful inspection of the annulus space area for detecting the sign of water leakage or inner shell abnormal shape were executed especially during high water level. After draining of water the tank was checked for any corrosion pitting etc.



Fig-11

CONCLUSION

In practice, the actual rate of gas/vapour replacement depends upon the volume flow of the incoming inert gas, its entry velocity and the dimensions of the tank vapour space. To provide a safety factor, the concentration should never exceed 8% in the vapor space of a tank or pipe that contains a hydrocarbon liquid. For complete gas/vapour displacement, it is important that the entry velocity of the incoming inert gas be high enough for the jet to reach the full vapour space; it is therefore important to confirm the ability of every installation using this principle to achieve the required degree of gas replacement throughout the tank vapour space. The storage tank and associated fittings, surrounding bunds, etc. should be maintained in a safe condition by suitably qualified and trained personnel. A review was undertaken during tank installation design to ensure that adequate access is allowed for all maintenance tasks to be undertaken safely. This may also include requirements for handrails, barriers, ladders, etc.

REFERENCES

- [1] Industrial-scale purging of ammonia by using nitrogen before environmental Discharge by Ahmet Ozan Gezerman, Int J Ind Chem 8 Sept 2016.
- [2] Guidance for Inspection of atmosphere, Refrigerated Ammonia storage Tanks, 2nd edition by Avenue E. van Nieuwenhuyse 6, Jan 2016.
- [3] Purging Principles and practice, third edition, June 2001, American Gas association, Washington DC.
- [4] The International organization for industrial Hazard management by Joiff, August 2015
